C47240

Exp. 12-31-07

May 1, 2006 PLANS APPROVAL DATE

DIST COUNTY

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this pla

To get to the Caltrans web site, go to: http://www.dot.ca.go.

GENERAL NOTES:

- A. For type of block and joint finish, see other sheets.
- B. When blocks are laid in stacked bond, ladder type, galvanized joint reinforcement shall be provided. A minimum of 2-12 gauge wires continuous at 4'-0" maximum to be used. Locate reinforcement in joints that are at the approximate midpoint between bond beams.
- C. Horizontal joints shall be tooled concave or may be weathered. Vertical joints shall be tooled concave or may be raked.
- D. For intermediate wall heights that are between the "H's" given, use the tabular information for the next higher "H".
- E. Masonry strengths are listed in the "SOUND WALL REINFORCEMENT TABLE". See Standard Plan B15-3.

N 94

DESIGN NOTES:

DESIGN

Uniform Building Code, 1997 Edition and the Bridge Design Specifications.

DESIGN WIND LOAD

DESIGN SEISMIC LOAD

20 psf


0.57 Dead load

REINFORCED CONCRETE f'c = 3.6 ksify = 60 ksi

CONCRETE MASONRY REGULAR STRENGTH

HIGH STRENGTH


f'm = 1500 psi fb = 495 psi f'm = 2000 psi fb = 660 psi f'm = 2500 psi fb = 830 psi fs = 24,000 psi fs = 24,000 psifs = 24,000 psi n = 25.8= 19.3 n = 15.5



SECTION A-A

For details not shown, see other sections.

H=6'-0" THRU H=10'-0'



For details not shown, see other sections.

H=12'-0" THRU H=16'-0"

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

SOUND WALL MASONRY BLOCK ON PILE CAP DETAILS (2)

B15-4